



General Stores: (0343) 2759151/9159/9160  
Mobile No.: +91-9434788015  
Fax No.: (0343)25467375  
Website: [www.nitdgp.ac.in](http://www.nitdgp.ac.in)  
Email: [drps@admin.nitdgp.ac.in](mailto:drps@admin.nitdgp.ac.in)

**NATIONAL INSTITUTE OF TECHNOLOGY DURGAPUR**  
MAHATMA GANDHI AVENUE, DURGAPUR – 713209 (WEST BENGAL), INDIA

Tender No. NITD/06/P&S/101/2017-18/Corri./01/18

Date: 13/04/2018

**CORRIGENDUM TO TENDER NOTICE NO. NITD/06/P&S/101/2017-18, DATED 31/03/2018.**

Following are the points (raised /enquired by prospective bidders) clarified during site visit & pre-bid meeting held on 10.04.18. Same are mentioned below for information of all concerned:

A) Lab furniture:

1. Water tap, Sink: Quality & Brand: No preferred brand. Quality to be maintained as per certifications.
2. Sink unit to be made of S. S. . Dimensions already mentioned in tender document.
3. Height of Counter (including Granite): 900mm, wherein the leg height will be 4"/105 mm approx..
4. Granite specification as per tender document. Only top side of granite should be polished & granite should have proper support at bottom to prevent breakage.
5. Hinges, locks, slides etc. to be of reputed brand with ISI mark.
6. Electrical & water main/mother connections will be provided by NIT Durgapur. Internal connections to be done by supplier/bidder.
7. GST percentage as applicable & as notified by GoI.
8. Payment terms will be as per tender document. No change in terms of payment.
9. Self-attested SEFA Certificate **to be uploaded** along with BIFMA, Greenguard etc. with Technical Bid. Self-attested **hard copy** of SEFA Certificate to be sent along with other required documents of Technical Bid. A criterion for having SEFA certification is not waived.
10. NSIC applicability: As per tender document.
11. Bank Solvency Certificate should be of Nationalized/Commercial Bank.
12. Authorized Service Centre should be within 300 km.
13. Drawings/layout should be submitted with technical bid.
14. As requested for no further AutoCAD drawings will be provided by the Institute. Present bidders were already permitted to visit proposed lab site on pre-bid date. Any site visits to be made with prior intimation & approval.
15. Material to be CRCA wherever specified in tender document.

B) For item no. 1 & 2: No further drawing/design will be provided. Items are to be as per specification, of best quality & ensuring proper stability of the table. No chairs are included in the meeting table.

**All other terms and conditions, specifications etc. of the original tender notice remain unchanged.**

**Dy. Registrar(P&S)** 13/04/18

Copy to: 1. Institute website, 2. CPPP